



Wiskerchen Cheese Inc. SOP

Title: Water Sampling

2.070

Issue Date: 6/15/10	Written By: Jesse Norton	Approved By: John Wiskerchen	Revision # 1	Revision Date: 10/29/13	Revised By: Abby Hoffman	Supersedes: 6/15/10	Page 1 of 1
------------------------	-----------------------------	---------------------------------	-----------------	----------------------------	-----------------------------	------------------------	-------------

Sample Preparation:

1. Label the sample bottle with the location to be tested.
2. Sample bottle must be a sterile and capable of holding 120 ml of sample.

Sampling:

- a. Store unopened sample bottles at <77 °F.
- b. Allow water to run from the location to be tested. If possible run for 2-3 minutes before sampling.
- c. If applicable heat sterilize the water tap before sampling by heating with a propane torch.
- d. Aseptically open your labeled sample container and fill it with at least 120 ml of sample.
- e. Aseptically seal the sample.
- f. Refrigerate sample until it can be sent out.
- g. Water samples must be tested within 24 hours of sampling.

Approved By: _____

Date: _____