



Wiskerchen Cheese Inc. SOP

Title: Emergency Boiler Shut Down

2.020

| | | | | | | | |
|-----------------------|-----------------------------|---------------------------------|-------------------|----------------|-------------|-------------|-------------|
| Issue Date: 4/5/11 | Written By: Jesse Norton | Approved By: John Wiskerchen | Revision # New | Revision Date: | Revised By: | Supersedes: | Page 1 of 1 |
|-----------------------|-----------------------------|---------------------------------|-------------------|----------------|-------------|-------------|-------------|

Boiler #1 – Primary Boiler 170 h.p. – East Boiler Room

1. Locate Boiler Controls wall switch on west wall.
2. Move switch down to off position.
3. Locate Boiler Blower Motor fuse box on west wall.
4. Move handle down to off position.

Boiler #2 – Back-Up Boiler 75 h.p. – West Boiler Room

1. Locate Boiler Controls wall switch on east wall.
2. Move switch down to off position.
3. Locate Boiler fuse box on east wall.
4. Move handle down to off position.

Approved By: _____

Date: _____